



WARNING:
Live Parts. Disconnect before servicing. Disconnect provided by installer, located remotely.
Panel Protected by circuit breaker or equivalent current limiting device.
Use only copper conductors rated only @ 60 degree celsius minimum.

Engineering Standards			
RISS16_01.10			
Retrofit Interior 16 Relay, Bottom Mount, 2-Button LVS			
Rev: 4	Type:	Date: 01-20-15	Job #:
BLUE RIDGE TECHNOLOGIES™ UNIFIED LIGHTING CONTROL		Engineered:	NB
		Drawn:	NB
		Checked:	
1 of 1			