


**WARNING:**  
Live Parts. Disconnect before servicing. Disconnect provided by installer, located remotely.  
Panel Protected by circuit breaker or equivalent current limiting device.  
Use only copper conductors rated only @ 60 degree celsius minimum.

Engineering Standards  
RISS48\_01.00

Retrofit Interior 48 Relay, Bottom Mount, CTS

Rev: 4	Type:	Date: 01-20-15	Job #:
 UNIFIED LIGHTING CONTROL			Engineered: NB
			Drawn: NB
			Checked:

1 of 1